



TRANSCURE LABORATORY
GATE 3 GROVE AVE
(PO Box 660)
MARLESTON SA 5033
Ph: (08) 8152 0092
Fax: (08) 8234 2442



Accreditation Number
11727

Certificate of Analysis (for insulating oil only)

Date of Issue : 5/09/2024
Client Name : Auspower HVPS
Address : Not stated
Phone : 0414 482 256
Purchase Order Number: Not stated
Contact: John Arthur
Date Received : 05/09/24 **Date Tested :** 05/09/24

Test method used: Internal test method TM 160

Lab ID #	Location	Manufacturer	Transformer Name/ Equipment Number	Serial Number	PCB Total (mg/kg)
24090071	23000lt Storage Tank	23000lt Storage Tank	Storage Tank	PCB	<2

Comments:

1. In case of Transcure was responsible for collection of these samples, this sampling activity is not covered by NATA accreditation
2. Limit of detection 0.4mg/kg.
3. A result of <2 Positive indicates PCB's were detected but were below 2 mg/kg.
4. The estimated uncertainty of measurement (including sampling process) for these test results are ± 20%
5. This certificate supercedes all previous issued reports of same number by the issue date.
6. All information is supplied by customer, except for the results.

Copies:- Transcure File

Accredited for compliance with ISO/IEC 17025-Testing
This report shall not be reproduced except in full.

Authorised by:

Hiep Quach
Authorised Signatory